

# BILLS OF QUANTITIES

PROJECT :NATIONAL LAW SCHOOL OF INDIA UNIVERSITY, BENGALURU

LOCATION: BENGALURU

DESCRIPTION : PUBLIC ADDRESS SYSTEM

| SL NO | DESCRIPTION  | UNIT | QTY | RATE | AMOUNT | REMARKS |
|-------|--|------|-----|------|--------|---------|
| 1.0   | Supplying, installing, testing and commissioning Digital Audio Amplifier designed for audio networks of up to Required DAA amplifiers terminating at a DVC Digital Voice Command. Each DAA shall be capable of accessing and processing one of up to Required audio channels on the DVC audio loop, amplifying the signal, and distributing it via four Class B or two Class A outputs at 50 watts. DAA-50 amplifiers can store backup alarm and trouble messages, and provide an adjustable background music input. An optional Firefighter's telephone riser on each DAA amplifier shall supports FFT communications riser.<br>MAKE:NOTIFIER (PART No. : DAA2-5070E+CHS-BH1) |      |     |      |        |         |
|       | Supply   | Nos. | 1   |      |        |         |
|       | Installation   | Nos. | 1   |      |        |         |
| 2.0   | Supply & installation of EQ 'D' SIZE cabinet for housing 4 No.of Amplifier.<br>Make: Notifier(Part Code: EQBB-D4+EQDR-D4)  |      |     |      |        |         |
|       | Supply   | Nos. | 1   |      |        |         |
|       | Installation   | Nos. | 1   |      |        |         |
| 3.0   | Supplying, installing, testing and commissioning of Remote microphone with Zone selector in a proper housing to mount zone selector and mic.<br>MAKE:NOTIFIER (PART No. : RM-1 with ACM-24AT+ CAB-RM)  |      |     |      |        |         |
|       | Supply   | Nos. | 0   |      |        |         |
|       | Installation   | Nos. | 0   |      |        |         |
| 4.0   | Supplying, installing, testing and commissioning of 2 W ceiling mounted type UL listed speakers with multi-tapping capable to produce minimum sound level of 75db at 3m distance.<br>MAKE:NOTIFIER (PART No. : NF-SP100CI/UL)<br>Note : Colour as per Approval   |      |     |      |        |         |
|       | Supply   | Nos. | 268 |      |        |         |

**BILLS OF QUANTITIES****PROJECT :NATIONAL LAW SCHOOL OF INDIA UNIVERSITY, BENGALURU****LOCATION: BENGALURU****DESCRIPTION : PUBLIC ADDRESS SYSTEM**

| SL NO                                 | DESCRIPTION   | UNIT | QTY | RATE | AMOUNT | REMARKS |
|---------------------------------------|---|------|-----|------|--------|---------|
|                                       | Installation  | Nos. | 268 |      |        |         |
| 6.0                                   | Back box for ceiling mounted speakers   |      |     |      |        |         |
|                                       | Supply  | Nos. | 268 |      |        |         |
|                                       | Installation  | Nos. | 268 |      |        |         |
| 7.0                                   | Supply and installation of 2C x 1.5 Sqmm FRLS copper twisted shielded cable for Public address system.            |      |     |      |        |         |
|                                       | Supply  | Rmt. | 200 |      |        |         |
|                                       | Installation  | Rmt. | 200 |      |        |         |
| 8.0                                   | Supply and Installation of 25mm dia PVC FRLS Conduit - 2mm thick including all accessories like bend, collar etc. |      |     |      |        |         |
|                                       | Supply  | Rmt  | 200 |      |        |         |
|                                       | Installation  | Rmt  | 200 |      |        |         |
| 9.0                                   | Supply and installation of 20mm PVC flexible conduit  |      |     |      |        |         |
|                                       | Supply  | Rmt  | 268 |      |        |         |
|                                       | Installation  | Rmt  | 268 |      |        |         |
|                                       |   |      |     |      | -      |         |
| <b>TOTAL OF PUBLIC ADDRESS SYSTEM</b> |   |      |     |      | -      |         |