



- GENERAL NOTES:**
1. THIS DRAWING SHALL BE READ IN CONJUNCTION WITH ALL RELEVANT ARCHITECTURAL, STRUCTURAL AND OTHER SERVICES DRAWINGS.
 2. ANY DISCREPANCY NOTICED SHALL BE BROUGHT TO THE ATTENTION OF THE CONSULTANTS AND RESOLVED PRIOR TO PROCUREMENT / EXECUTION OF WORKS.
 3. ALL DIMENSIONS ARE IN MILLIMETERS AND ALL LEVELS ARE IN METERS UNLESS OTHERWISE INDICATED.
 4. FOLLOW WRITTEN DIMENSIONS ONLY. DO NOT SCALE THE DRAWING.

SL. NO.	RAW POWER SOCKET SYMBOLS DESCRIPTION	SYMBOL
1	1 NO OF 16A 3PIN SWITCHED SOCKET CONTROLLED BY 1 NOS OF 20A SWITCH (WITHOUT BOX ON FURNITURE)	2P
2	1 NO OF 10A SWITCH (WITHOUT BOX ON FURNITURE)	2P
3	1 NO OF 10A 3PIN SWITCHED SOCKET CONTROLLED BY 1 NOS OF 20A SWITCH (WITHOUT BOX ON FURNITURE)	2P
4	1 NO OF 6A 3PIN SWITCHED SOCKET CONTROLLED BY 1 NOS OF 10A SWITCH (WITH BOX)	2P
5	1 NO OF 6A 3PIN SWITCHED SOCKET (WITH BOX)	2P
6	1 NO OF 10A 3PIN SWITCHED SOCKET CONTROLLED BY 1 NOS OF 10A SWITCH (WITH BOX)	2P
7	1 NO OF 10A 3PIN SWITCHED SOCKET CONTROLLED BY 1 NOS OF 20A SWITCH (WITH BOX)	2P
8	TELEPHONE	1P
9	DATA PORT	1P
10	1 SET OF 6/16A INTEL SOCKET CONTROLLED BY 1A SWITCH IN 3 ROOMS ON RAW POWER OTHER ON UPS + 2 DATA PORTS WITH HDMI PROVISION	2P
11	1 NO OF 10A 3PIN SWITCHED SOCKET CONTROLLED BY 1 NOS OF 20A SWITCH + 2 DATA+HDMI PORTS (UPS METRICK TYPE)	2P
12	3P MCB IN IP43 POLY CARBONATE ENCLOSURE	1P
13	4P MCB IN IP43 POLY CARBONATE ENCLOSURE	1P

SL. NO.	UPS POWER SOCKET SYMBOLS DESCRIPTION	SYMBOL
1	2 NO OF 6/16A 3PIN SWITCHED SOCKET CONTROLLED BY 1 NOS OF 20A SWITCH (WITHOUT BOX ON FURNITURE)	2P
2	1 NO OF 6A 3PIN SWITCHED SOCKET CONTROLLED BY 1 NOS OF 10A SWITCH (WITH BOX)	2P
3	2 NO OF 6A 3PIN SWITCHED SOCKET CONTROLLED BY 1 NOS OF 10A SWITCH (WITH BOX)	2P
4	1 NO OF 6/16A 3PIN SWITCHED SOCKET CONTROLLED BY 1 NOS OF 20A SWITCH (WITH BOX)	2P

SYMBOL	DESCRIPTION
200mm (W) x 50mm (H) PERFORATED TYPE CABLE TRAY	
100mm (W) x 50mm (H) PERFORATED TYPE CABLE TRAY	
150mm (W) x 50mm (H) PERFORATED TYPE CABLE TRAY	
150mm (W) x 50mm (H) LADDER TYPE CABLE TRAY	
300mm (W) x 50mm (H) LADDER TYPE CABLE TRAY	
400mm (W) x 50mm (H) LADDER TYPE CABLE TRAY	
600mm (W) x 50mm (H) LADDER TYPE CABLE TRAY	
800mm (W) x 50mm (H) PERFORATED TYPE CABLE TRAY	
750mm (W) x 75mm (H) LADDER TYPE CABLE TRAY	
1000mm (W) x 75mm (H) LADDER TYPE CABLE TRAY	

REV. NO.	REVISION DESCRIPTION	DATE
R0	ISSUED FOR TENDER	11.02.2025
R1	AS PER REVISED ARCHITECT	06.03.2025
R2		
R3		
R4		
R5		
R6		

PROJECT

JSW ACADEMIC BLOCK - NLSIU
NEW ACADEMIC BLOCK Gnana Bharathi Main Rd, Teachers Colony, Naagarabhaavi, Bengaluru, Karnataka 560072

CLIENT

NATIONAL LAW SCHOOL OF INDIA UNIVERSITY
Gnana Bharathi Main Rd, Teachers Colony, Naagarabhaavi, Bengaluru, Karnataka 560072

ARCHITECT

HUNDREDHANDS
9/2, Madras Bank Road, Shanthala Nagar, Ashok Nagar, Bengaluru, Karnataka 560001

MEPF AND IBMS CONSULTANTS

LEAD CONSULTANCY & ENGINEERING SERVICES (INDIA) Pvt.Ltd.
Eco Friendly Solutions
NO.2722, 1st FLOOR, 80 FEET ROAD, INDIRA NAGAR II STAGE, BENGALURU-560038, KARNATAKA.
Phone: +91 80 42980111, Web: lcsind.org
India: Bengaluru | Mumbai | Pune | Gurgaon | Chennai | Hyderabad | Kolkata

DRAWING TITLE			
BASEMENT POWER & CABLE TRAY LAYOUT			
DRAWN BY	HMD	DRAWING NUMBER	SCALE
CHECKED	SSK	LCES-NLS-E-201	SHEET SIZE
APPROVED	PD	REV - R1	DATE

DRAWING ISSUED FOR

TENDER

THIS DRAWING IS SOLE PROPERTY OF **LEAD CONSULTANCY**
USE OF THIS DRAWING FOR ANY PURPOSE OTHER THAN THAT MENTIONED TO BE DONE ONLY AFTER THEIR PRIOR APPROVAL.